



ALING CONEL d.o.o.

Železnička 10, 21432 GAJDOBRA, SERBIA

Tel: +381 21/762-674, 762-586; Fax: +381 21/762-779,

E-mail: info@aling-conel.com ; www.aling-conel.com

DEKLARACIJA O USAGLAŠENOSTI

No. 026/25

PROIZVOĐAČ	ALING-CONEL d.o.o. Železnička 10, 21432 Gajdobra, SRBIJA	
PROIZVOD	Kutije instalacione za ugradnju na zid	
TRGOVAČKA MARKA	--	
MODEL PROIZVODA / TIP	art.9201.xx; art.9202.xx; art.9203.xx; art.9204.xx; art.92021.xx; art.92031.xx; art.92041.xx	
OSNOVNI PODACI O PROIZVODU	IP44 (art.9201.xx); IP66 (art.9202.xx, art.9203.xx, art.9204.xx, art.92021.xx, art.92031.xx, art.92041.xx) temperaturni rang -25°C ... +60°C	
PROPISI/ HARMONIZOVANI STANDARDI	Reference	Naslov
	IEC 60670-1:2015	Boxes and enclosures for electrical accessories for household and similar fixed electrical installations - Part 1: General requirements
	IEC 60670-22:2003+A1:2015	Boxes and enclosures for electrical accessories for household and similar fixed electrical installations - Part 22: Particular requirements for connecting boxes and enclosures
	SRPS EN IEC 60670-1: 2021	Kutije i kućišta za elektroinstalacioni pribor za domaćinstvo i slične fiksne električne instalacije - Deo 1: Opšti zahtevi
SRPS EN 60670-22: 2008	Kutije i kućišta za električni pribor za domaćinstvo i slične fiksne instalacije - Deo 22: Posebni zahtevi za kutije i kućišta za povezivanje	
PROIZVOD USAGLAŠEN SA	Referenca	Naslov
	Sl. glasnik RS 25/2016 i 21/2020	Pravilnik o električnoj opremi namenjenoj za upotrebu u okviru određenih granica napona
DODATNE INFORMACIJE	1. Ovi proizvodi su ispitani u skladu sa standardima IEC 60670-1:2015 i IEC 60670-22: 2003+A1:2015, izveštaj o ispitivanju No. T211-0275/25, CB certifikat SI-12121.	

Mesto: Gajdobra,
Datum: 04. april 2024.



Jovica Ristić, Direktor razvoja i kvaliteta